

**When signal goes from 0V to 5V, there should first be a 5 second delay then the Relay_A should be switched ON for 3 seconds only.
 When signal later goes from 5V to 0V, there should again be a 5 second delay and then Relay_B should be turned ON for 3 seconds only.**

